

## **PLANNING AND DEVELOPMENT SERVICES**

1001 Sarasota Center Blvd., Sarasota, FL 34240 – (941)861-6678  
4000 S. Tamiami Trail, Rm. 122, Venice, FL 34293 – (941)861-3029

### **Florida Residential Fuel Gas Code, 7<sup>th</sup> Edition**

#### **2017-2020 Significant Changes (Fuel Gas Code)**

##### **G2406.2 (303.3) Prohibited Locations for Appliances**

A gas-fired clothes dryer is now allowed to be installed in a bathroom or toilet room where a permanent opening communicates with other permitted spaces.

##### **G2411.2 (310.2) Electrical Bonding of CSST**

The existing provisions for electrical bonding apply to CSST without the arc-resistant jacket or coating and a new section addresses electrical continuity and bonding of arc-resistant CSST.

##### **G2411.3 (310.3) Arc-resistant CSST**

New Section added.

##### **G2414.4.2 (403.4.2), G2414.10.1 (403.10.1) Schedule 10 Steel Gas Piping**

Schedule 10 steel pipe can now be used for fuel-gas piping with limitations on fitting connections.

##### **G2415.11 (404.11) Protection Against Corrosion**

##### **G2420.5.1 (409.5.1) Shutoff Valve Location.**

Shutoff valves serving movable appliances are considered as meeting the requirements for access.

##### **G2420.6 New Section**

Support for shutoff valves in tubing systems. Rigid support separate from the tubing to prevent damage at the valve connection is now required.

##### **G2447.2 (623.2)**

Commercial cooking appliances are now permitted in dwelling units when installed in accordance with an engineered design and the manufacturer's instructions.